

Subject: RE: [EXTERNAL] RE: [EXTERNAL] Goldsborough HG5 8NT
From: "Percival, Mark" <Mark.Percival@northernpowergrid.com>
Date: 18/08/2017 08:42
To: Ben Holmes <ben@dhlandstrategy.co.uk>

Hi Ben,

You will more than likely need a ground mounted substation in the new housing estate. The HV cable that crosses the land can be utilised to supply that electric.

You are better making a formal approach for a budget quote then you will know where you stand.

Many thanks
Mark

From: Ben Holmes [mailto:ben@dhlandstrategy.co.uk]
Sent: 17 August 2017 10:44
To: Percival, Mark
Subject: [EXTERNAL] RE: [EXTERNAL] Goldsborough HG5 8NT

Hi Mark,

When we offer a replacement route for the underground cable, do you think we will be able to make a connection to supply approx. 40 houses on the new site?

Kind regards,

Ben


On 15 August 2017 at 09:27 "Percival, Mark" <Mark.Percival@northernpowergrid.com> wrote:

Hi Ben,

There are two underground cables in the field, one off pole 12 that loops round and out through Holly Garths garden. The other runs diagonally across the field from pole 11 North West towards the school.

I would recommend getting a full copy of our safe digs and also cable ID the cables before you do any excavations.

e-mail – safediggingplans@northernpowergrid.com



GOLDENBROUGH
WEST SW
11 10 20

CRICKET GROUND
0032
50

Path



Many thanks

Mark

From: Percival, Mark
Sent: 09 August 2017 15:01
To: 'Ben Holmes'
Subject: RE: [EXTERNAL] Goldsborough HG5 8NT

Hi Ban,

The overhead line is cover by a wayleave agreement ref number 2001 been paid annually in March to Webster Partners.

You would need a valid reason and planning permission for the removal, plus it might help if your client offered a route for the replacement underground cable.

Send your request to Diversions@northernpowergrid.com with the planning approval reference number.

Many thanks

Mark

From: Ben Holmes [mailto:ben@dhlandstrategy.co.uk]
Sent: 09 August 2017 14:26
To: Percival, Mark
Subject: [EXTERNAL] Goldsborough HG5 8NT

Hi Mark,

We're working on a site in Goldsborough (identified as GB4 on the attached Plan) for residential development.

It has some electricity lines running across the middle of the site, and the landowner, Henry Webster, receives some annual payments from you, although he's not too sure of the details.

Do you happen to know whether these would be wayleaves or easements? And would we be able to divert their routes if needs be?

Any advice you can offer would be greatly appreciated.

Many thanks,

Ben Holmes
0777 157 4745

E mail Disclaimer

You agree that you have read and understood this disclaimer and you agree to be bound by its terms.
The information contained in this e-mail and any files transmitted with it (if any) are confidential and intended for the addressee only. If you have received this e-mail in error please notify the originator.
This e-mail and any attachments have been scanned for certain viruses prior to sending but Northern Powergrid Holdings Company nor any of its associated companies from whom this e-mail originates shall be liable for any losses as a result of any viruses being passed on.
No warranty of any kind is given in respect of any information contained in this e-mail and you should be aware that it might be incomplete, out of date or incorrect. It is therefore essential that you verify all such information with us before placing any reliance upon it.
Northern Powergrid Holdings Company
Lloyds Court
78 Grey Street
Newcastle upon Tyne
NE1 6AF
Registered in England and Wales: Number 3476201

E mail Disclaimer

You agree that you have read and understood this disclaimer and you agree to be bound by its terms.
The information contained in this e-mail and any files transmitted with it (if any) are confidential and intended for the addressee only. If you have received this e-mail in error please notify the originator.
This e-mail and any attachments have been scanned for certain viruses prior to sending but Northern Powergrid Holdings Company nor any of its associated companies from whom this e-mail originates shall be liable for any losses as a result of any viruses being passed on.
No warranty of any kind is given in respect of any information contained in this e-mail and you should be aware that it might be incomplete, out of date or incorrect. It is therefore essential that you verify all such information with us before placing any reliance upon it.
Northern Powergrid Holdings Company
Lloyds Court
78 Grey Street
Newcastle upon Tyne
NE1 6AF
Registered in England and Wales: Number 3476201
